

BRE Global Ireland

Notified Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

Certificate of constancy of performance

2831-CPR-F2567

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s).

VG-6847 4 Loop Analogue Addressable Control and Indicating Equipment

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trademark of: and produced in the manufacturing plant(s):

V-GREAT GLOBAL CORPORATION
Second Floor, Capital City,
Independence Avenue,
P.O. Box 1008,
Victoria, Mahe,
Seychelles

Tianjin VSAIL Intelligent Fire Technology Co. Ltd.,
No. 401, Building 6,
No. 1 Xinxing Road,
Wuqing Development Zone,
Tianjin 301700,
P.R. China

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-2:1997 + A1:2006 Control and Indicating Equipment
EN 54-4:1997 + A1:2002 + A2:2006 Power Supply Equipment

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 16 October 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



S. David, Certification Engineer

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 16 October 2019

Issue Date: 19 September 2025

Issue Number: 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie

BRE Global Ireland

Approved Body No. 2831

BRE Global Assurance (Ireland) Limited
DCU Alpha, Old Finglas Road
Glasnevin, Dublin, D11 KXN4
Ireland
T: +353 (0) 18824344
E: enquiries@breglobalireland.ie
www.breglobalireland.ie

APPENDIX to Certificate of constancy of performance: 2831-CPR-F2567

VG-6847 4 Loop Analogue Addressable Control and Indicating Equipment

Incorporating the following modules:

VSL2.908.146 Main Board
VSL2.908.149 Indication board
VSL2-908-150 Zone Board
VSL2.908.152 I/O Board
VSL2.908.153 Loop Card
VSL2.908.155 Terminal board
VSL2.908.162 Control Board
VSL2.908.169 Power Board
LRS-150-24 MEAN-WELL Power Supply module

Certified with the following option with requirements for EN 54-2:

- 7.8 Output to fire alarm devices
- 7.10.1 Outputs to fire protection equipment (Type A)
- 7.10.2 Outputs to fire protection equipment (Type B)
- 7.10.3 Outputs to fire protection equipment (Type C)
- 7.10.4 Fault monitoring of fire protection equipment
- 7.11 Delays to outputs
- 7.12.1 Dependencies on more than one alarm signal (Type A dependency)
- 7.12.2 Dependencies on more than one alarm signal (Type B dependency)
- 7.12.3 Dependencies on more than one alarm signal (Type C dependency)
- 7.13 Alarm Counter
- 9.5 Disablement of addressable point
- 10 Test condition

Notes:

1. The "Network Card VSL2-908-154" was fitted in the equipment but the scope of the approval does not include the operation of the Network functionality and EMC tests.
2. This approval does not constitute compliance with the fire detection and fire alarm systems requirements of EN 54-13.



S. David, Certification Engineer

On behalf of BRE Global Assurance (Ireland) Limited

Date of First Issue: 16 October 2019

Issue Date: 19 September 2025

Issue Number: 02

To check the validity of this certificate, please contact us on +353 (0) 18824344 or email enquiries@breglobalireland.ie