

Certificate of Product Approval

Certificate Number: 1174c-(cl-1) Issue: 02

LPCB

V-Great Global Corporation

Second Floor, Capital City Independence Avenue P O Box 1008 Victoria Mahe Seychelles

is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Alarm Warning Devices

VG-6734

VG-6737

(refer to Appendix for details)

Standards

EN 54-3:2001 + A1:2002 + A2:2006

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Malligan.
Signed for BRE Global Ltd

Peter Halligan

28 April 2017

09 May 2016

Date of First Issue





This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
LPCB is a Registered Trademark of the Building Research Establishment Ltd.







Appendix to Certificate No: 1174c-(cl-1)

Issue: 02

V-Great Global Corporation

Certified Product	Description	LPCB Ref.No.
VG-6734	Conventional Type A Sounder Strobe (VG-6711 Base) Notes: 1. Meets the requirements of EN 54-3 and approved at the following tones: 1) Tone 01, 2400Hz – 2900Hz @ 3 Hz 2) Tone 10, 500Hz – 1200Hz x 3, 3.5s on / 0.5s off	1174c/01
	2. The strobe function is not included within the scope of this approval	
VG-6737	Addressable Type A Indoor Digital Sounder Beacon (VG-6619 Base) Notes: 1. Meets the requirements of EN 54-3 and approved at the following tones: 1) Tone 00, 2400Hz – 2900Hz @ 3Hz 2) Tone 01, 2400Hz – 2900Hz @ 9Hz 3) Tone 08, 500Hz – 1200Hz x 3, 3.5s on / 0.5s off 4) Tone 14, 1500Hz – 2700Hz @ 3Hz	1174c/02
	2. The beacon function is not included within the scope of this approval	

Bases

VG-6711 Standard base VG-6619 Mounting base

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

f. Halligar.

Peter Halligan

28 April 2017

09 May 2016

Signed for BRE Global Ltd

Verifier

Date of Issue

Date of First Issue





This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit $\underline{www.redbooklive.com/check}, scan the QR tag or contact us.$

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com LPCB is a Registered Trademark of the Building Research Establishment Ltd.



