

Certificate of Product Approval

Certificate Number: 1174c-(cl-1)

Issue: 03

V-Great Global Corporation

Second Floor, Capital City
Independence Avenue
P O Box 1008
Victoria
Mahe
Seychelles

is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Alarm Warning Devices

VG-6734

VG-6737

(refer to Appendix for details)

Standards

EN 54-3:2014 + A1:2019

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

Z Major

Verifier

12 July 2023

Date of Issue

09 May 2016

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre

Appendix to Certificate No: 1174c-(cl-1) V-Great Global Corporation

Issue: 03

Certified Product	Description	LPCB Ref.No.
VG-6734	Conventional Type A Sounder Strobe (VG-6711 Base) Notes: 1. Meets the requirements of EN 54-3 and approved at the following tones: 1) Tone 01, 2400Hz – 2900Hz @ 3 Hz 2) Tone 10, 500Hz – 1200Hz x 3, 3.5s on / 0.5s off 2. The strobe function is not included within the scope of this approval	1174c/01
VG-6737	Addressable Type A Indoor Digital Sounder Beacon (VG-6619 Base) Notes: 1. Meets the requirements of EN 54-3 and approved at the following tones: 1) Tone 00, 2400Hz – 2900Hz @ 3Hz 2) Tone 01, 2400Hz – 2900Hz @ 9Hz 3) Tone 08, 500Hz – 1200Hz x 3, 3.5s on / 0.5s off 4) Tone 14, 1500Hz – 2700Hz @ 3Hz 2. The beacon function is not included within the scope of this approval	1174c/02

Bases

VG-6711 Standard base
VG-6619 Mounting base

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

Z Major
Verifier

12 July 2023
Date of Issue

09 May 2016
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
LPCB is a Registered Trademark of the Building Research Establishment Ltd.



bre