

Certificate of Product Approval

Certificate Number: 1174j-(cl-1)

Issue: 01

V-GREAT GLOBAL CORPORATION

Second Floor, Capital City,
Independence Avenue,
P.O. Box 1008,
Victoria,
Mahe,
Seychelles



is certified by BRE **Global** Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Control and Indicating Equipment

VG-6847

(refer to Appendix for details)

Standards

EN 54-2:1997 + A1:2006

EN 54-4:1997 + A1:2002 + A2:2006

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

E Mattie-Suleiman

Verifier

26 September 2018

Date of Issue

26 September 2018

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 1174j-(cl-1)

Issue: 01

V-GREAT GLOBAL CORPORATION

Certified Product	Description	LPCB Ref.No.
VG-6847	<p>4 Loop Analogue Addressable Control and Indicating Equipment</p> <p>Incorporating the following modules:</p> <ul style="list-style-type: none"> VSL2.908.146 Main Board VSL2.908.149 Indication board VSL2.908.155 Terminal board VSL2.908.162 Control Board VSL2.908.153 Loop Card VSL2.908.152 I/O Board VSL2.908.169 Power Board VSL7-820-150 Zone Board VSL7-820-154 Network Card LRS-150-24 MEAN-WELL Power Supply module <p>Certified with the following option with requirements for EN54-2:</p> <ul style="list-style-type: none"> 7.8 Output to fire alarm devices 7.10.1 Outputs to fire protection equipment (Type A) 7.10.2 Outputs to fire protection equipment (Type B) 7.10.3 Outputs to fire protection equipment (Type C) 7.10.4 Fault monitoring of fire protection equipment 7.11 Delays to outputs 7.12.1 Dependencies on more than one alarm signal (Type A dependency) 7.12.2 Dependencies on more than one alarm signal (Type B dependency) 7.12.3 Dependencies on more than one alarm signal (Type C dependency) 7.13 Alarm Counter 	1174j/01

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.


Signed for BRE Global Ltd

E Mattie-Suleiman
Verifier

26 September 2018
Date of Issue

26 September 2018
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 1174j-(cl-1)

Issue: 01

V-GREAT GLOBAL CORPORATION

Certified Product	Description	LPCB Ref.No.
	9.5 Disablement of addressable point 10 Test condition Notes: 1. The scope of the approval does not include the operation of the network functionality 2. This approval does not constitute compliance with the fire detection and alarm systems requirements of EN54-13.	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.


Signed for BRE Global Ltd

E Mattie-Suleiman
Verifier

26 September 2018
Date of Issue

26 September 2018
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com

LPCB is a Registered Trademark of the Building Research Establishment Ltd.

