

Certificate of Product Approval

V-GREAT GLOBAL CORPORATION

CERTIFICATE NUMBER	ISSUE	COMPANY ADDRESS
1174j-(cl-1)	02	Second Floor, Capital City, Independence Avenue, P.O. Box 1008, Victoria, Mahe, Seychelles

The named company is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

PRODUCTS	STANDARDS
Control and Indicating Equipment: VG-6847	EN 54-2:1997 + A1:2006 EN 54-4:1997 + A1:2002 + A2:2006

(refer to Appendix for details)

This certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 certificate being maintained.



Signed for

S. David
Verifier

11 September 2025
Date of Issue

26 September 2018
Date of First Issue



This certificate and appendix remain the property of BRE. and is issued subject to terms and conditions (for details visit www.redbooklive.com). To check the validity of this certificate and appendix please scan the QR tag, visit www.redbooklive.com or contact us.

LPCB® is a registered trademark of the Building Research Establishment Ltd.

BRE Global, Bucknalls Lane,
Watford, WD25 9XX
T: +44 (0)333 321 8811
E: enquiries@bregroup.com



Appendix to Certificate No: 1174j-(cl-1)

ISSUE
02

V-GREAT GLOBAL CORPORATION

Certified Product	Description	LPCB Ref No.
VG-6847	4 Loop Analogue Addressable Control and Indicating Equipment Incorporating the following modules: VSL2.908.146 Main Board VSL2.908.149 Indication board VSL2-908-150 Zone Board VSL2.908.152 I/O Board VSL2.908.153 Loop Card VSL2.908.155 Terminal board VSL2.908.162 Control Board VSL2.908.169 Power Board LRS-150-24 MEAN-WELL Power Supply module Certified with the following option with requirements for EN 54-2: 7.8 Output to fire alarm devices 7.10.1 Outputs to fire protection equipment (Type A) 7.10.2 Outputs to fire protection equipment (Type B) 7.10.3 Outputs to fire protection equipment (Type C) 7.10.4 Fault monitoring of fire protection equipment 7.11 Delays to outputs 7.12.1 Dependencies on more than one alarm signal (Type A dependency) 7.12.2 Dependencies on more than one alarm signal (Type B dependency) 7.12.3 Dependencies on more than one alarm signal (Type C dependency) 7.13 Alarm Counter 9.5 Disablement of addressable point 10 Test condition Notes:	1174j/01

This certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 certificate being maintained.


Signed for

S. David
Verifier

11 September 2025
Date of Issue

26 September 2018
Date of First Issue



This certificate and appendix remain the property of BRE. and is issued subject to terms and conditions (for details visit www.redbooklive.com). To check the validity of this certificate and appendix please scan the QR tag, visit www.redbooklive.com or contact us.

LPCB® is a registered trademark of the Building Research Establishment Ltd.

BRE Global, Bucknalls Lane,
Watford, WD25 9XX
T: +44 (0)333 321 8811
E: enquiries@bregroup.com



Appendix to Certificate No: 1174j-(cl-1)

ISSUE
02

V-GREAT GLOBAL CORPORATION

	1. The “Network Card VSL2-908-154” was fitted in the equipment but the scope of the approval does not include the operation of the Network functionality and EMC tests. 2. This approval does not constitute compliance with the fire detection and fire alarm systems requirements of EN 54-13.	
--	--	--

This certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 certificate being maintained.

	S. David	11 September 2025
Signed for	Verifier	Date of Issue
26 September 2018		
Date of First Issue		



This certificate and appendix remain the property of BRE. and is issued subject to terms and conditions (for details visit www.redbooklive.com). To check the validity of this certificate and appendix please scan the QR tag, visit www.redbooklive.com or contact us.

LPCB® is a registered trademark of the Building Research Establishment Ltd.

BRE Global, Bucknalls Lane,
Watford, WD25 9XX
T: +44 (0)333 321 8811
E: enquiries@bregroup.com

